

Owner's Manual



Model 82020 GFCI Receptacle Tester



CAUTION: Read, understand and follow Safety Rules and Operating Instructions in this manual before using this product.

ONE YEAR FULL WARRANTY

CRAFTSMAN ONE YEAR FULL WARRANTY

FOR ONE YEAR from the date of purchase, this product is warranted against defects in material or workmanship. A defective product will be replaced free of charge. For warranty coverage details to obtain free replacement, visit the web site: www.craftsman.com. This warranty is void if this product is ever used while providing commercial services or if rented to another person. This warranty gives you specific legal rights, and you may also have other rights which vary from state to state.

Sears Brands Management Corporation, Hoffman Estates, IL 60179

For Customer Assistance Call 9am - 5pm (ET) Monday through Friday 1-888-326-1006

WARNING: USE EXTREME CAUTION IN THE USE OF THIS DEVICE. Improper use of this device can result in injury or death. Follow all safeguards suggested in this manual in addition to the normal safety precautions used in working with electrical circuits. DO NOT service this device if you are not qualified to do so.

Sears Brands Management Corporation, Hoffman Estates, IL 60179 U.S.A.
www.craftsman.com 122112

OPERATION

Standard Receptacle

1. Always test on a known good circuit before use.
2. The test result codes are printed on the device.
3. Refer all indicated problems to a qualified electrician.
4. The tester will not indicate the quality of the ground connection, 2 hot wires in a circuit, a combination of defects, or reversal of ground and neutral conductors.

GFCI Receptacle

1. Before using the tester, press the TEST button on the installed GFCI receptacle, the GFCI should trip. If it does not, do not use the circuit and call a qualified electrician. If it does trip, press the RESET button on the receptacle and plug in the tester.
2. Verify that the wiring is correct as described above.
3. Press and hold the test button on the tester for at least 6 seconds, the indicator lights on the tester will shut off when the GFCI trips.
4. When testing a GFCI installed in a 2-wire (non-grounded) system, the tester may indicate a faulty GFCI. If this occurs, press the TEST and RESET buttons on the GFCI to determine proper operation.

TROUBLESHOOTING

There may be times when your meter does not operate properly.

If The Meter Does Not Operate:

1. Always read all the instructions in this manual before use.
2. If You Do Not Understand How the Meter Works:

Call our Customer Service Line 1-888-326-1006

SERVICE AND PARTS

For replacement parts shipped directly to your home
Call 9 am – 5 pm Eastern Time, Monday through Friday

1-888-326-1006